



Reactor Plant Safety Course FY2010
Winter Course

Application of Installation Permission of Nuclear Power Plant (NPP)

Makoto SAWADA

January 27th, 2011

*International Technology Information & Training Center,
Tsuruga Office, JAEA*



Presentation Contents

- 1. Positioning of Application of Installation Permission in the Law***
- 2. Relation between Safety Assessment and Installation Permission of NPP***
- 3. Configuration of Application Form for Installation Permission of NPP***
- 4. Contents of Attachment Materials***
- 5. Actual Example of Installation Permission of NPP***
- 6. Comparison with Standard Review Plan of Safety Analysis Report for NPP by U.S.NRC***

(Appendix)

Preliminary Safety Analysis Report (PSAR)

(Standard Review Plan for the Review of Safety Analysis Reports for NPP: LWR Edition)



1. Positioning of Application of Installation Permission in the Law

System of Law Concerning Safe Regulation of NPP

Atomic Fundamental Law

- Objective

Energy resources are secured by progressing research and development and utilization of nuclear.

- Basic Policy

Nuclear development and use is restricted to the purpose of peace and its results should be opened and should be contributed to international cooperation spontaneously.


Act on the Regulation of Nuclear Source Material, Nuclear Fuel Material and Reactors

Main Regulation Matters

- ◆ **Installation Permission of NPP**
- ◆ **Permission of Safety Operational Program**
- ◆ **Security Inspection**
- ◆ **Permission of Regulation regarding Physical Protection for Nuclear Materials**




Positioning of Application of Installation Permission in Construction Process of NPP (1/2)





Positioning of Application of Installation Permission in Construction Process of NPP (2/2)






Main Events until Starting Construction (for Monju)

1970	~	1976	1977	1978	1979	1980	1981	1982	1983	1984	1985	1986	1987		
△/4		△/7	△/8	△/3	△/2	△/9	△/12	△/5	△/7	△/5	△/12	△/10	△/2	△/7	△/9
Candidate Site's Selection		Start of Environmental Surveys	Finish of Environmental Surveys	Start of Environmental Examination	Modification of Some Parts of Plan	Finish of Environmental Examination	Application of Installation Permission	Cabinet Construction Consent	Open Hearing	Getting of Installation permission	Approval Application of Construction Method	Start of Construction	Start of Basement Concrete	Start of C/V Construction	Finish Approval Application of Construction Method
<p>Environmental Surveys & Examination for at. 4 years</p>						<p>Safety Assessment for at. 3 years</p>			<p>Construction (for at. 6 years)</p>						



2. Relation between Safety Assessment and Installation Permission of NPP

Installation Permission of NPP



Screening Standard of Safety Assessment consisting of a total of 59 items



Main Flow until Getting Permission of Installation of NPP

Application of Installation Permission of NPP to METI (or MEXT)



Implementation of **Safety Assessment** by **Screening Committees** organized by METI



Final Check by “**Atomic Committee**” and “**Atomic Safety Committee**”



Pass the Final Check



Giving Installation Permission of NPP from METI (or MEXT)

- ◆ Screening Committee for Core Design
- ◆ Screening Committee for Structure Design
- ◆ Screening Committee for Seismic Design
- ◆ Screening Committee for Sodium Handling (FBR)

Check Application Contents with Permission Criterion of Installation Permission of NPP (Non-Technical Matter)



Permission Criterion for Installation of NPP

The concerned minister (METI or MEXT) has to interview the opinion of both committees before giving the permission to the plant owner.

Atomic Committee

Peaceful Use

There is no possibility that a reactor may be used besides the purpose of peace.

Planned Implementation

There is no possibility that giving permission never causes the trouble to the planned implementation of nuclear development and use.

Foundation

A plant owner has enough finance to be constructed a reactor plant.

Atomic Safety Committee

Technical Capability

A plant owner has enough technical capability for construction and operation of a reactor plant.

Prevention of Disaster

To prevent occurring disaster, a reactor plant must be taken suitable measures.



Screening Standard of Safety Assessment (59 Items)

System for Screening	Main Screening Contents	Number
1. Reactor Facility Whole	Conformity Standard, Natural Phenomenon, Fire, etc.	10 Items
2. Reactor Core and Reactor Shutdown System	Self Regulating Characteristics, Shutdown Capability, etc.	8 Items
3. Heat Removal System	Soundness of Pressure Boundary, ECCS, etc.	9 Items
4. Reactor Containment Vessel	Isolation Function, Ventilation Control, etc	6 Items
5. Reactor Protection System	Redundancy, Diversity, etc.	7 Items
6. Control Room and Emergency System	Emergency Reactor Shutdown Function from Outside of Control Room, etc.	6 Items
7. Instrumentation & Control System and Power System	Instrumentation & Control System and Power System	2 Items
8. Fuel Handling System	Fresh/Spent Fuel Handling, Critical Prevention, etc.	3 Items
9. Radioactive Waste Disposal System	Disposal of Gas, Liquid and Solid Radioactive Wastes	4 Items
10. Radiation Control	Radiation Protection, Monitoring, etc.	4 Items



Example of Safety Design Assessment Standard (Extract)

<Extract 1/2>

V) Reactor Core and Shutdown System

● Standard-11: Core Design

1. Core design should be a design which does not exceed the permissible design limit of fuel during normal and abnormal operations by functions of heat transfer system, reactor shutdown system, instrumentation control and safety protection system.
2. Core subassembly should be a design which can secure cooling during all operation modes including a accident.

● Standard-13: Core Characteristic

A core should be a design which has an inherent safety (negative feedback characteristic) and also can control easily even if power oscillation occurs.



<Extract 2/2>

VI) Reactor Heat Transfer System

● Standard-19: Soundness of a Reactor Coolant Pressure Boundary

1. A reactor coolant pressure boundary should be a design which can secure its soundness during normal and abnormal operation modes.
2. As a general rule, the piping system connected to reactor heat transfer system should have isolation valves.

● Standard-25: Emergency Core Cooling System (ECCS)

1. ECCS should be a design which can prevent a serious damage of fuel for the accident of loss of coolant and moreover can restrict a reaction between fuel cladding metal and a water to a small quantity sufficiently.
2. ECCS should have redundancy or diversity and independency in order to perform its safety function completely even if an external power cannot be used in addition to assumption of the single failure of an equipment.
3. ECCS should be a design which can conduct test and inspection periodically and can carry out test and inspection of each system independently for assuring its soundness and redundancy.



3. Configuration of Application Form for Installation Permission of NPP

Application Form

Main Text

- 1) Name and address of the applicant, Representative name
- 2) Purpose of using
- 3) Reactor type, thermal output and number of the reactors
- 4) Name of the reactors and address of installation
- 5) Location, structure and equipment of the reactor facilities
- 6) Construction Plan
- 7) Kind of Nuclear Fuel Materials
- 8) Method for disposing of spent fuel

Attachment Materials*

— Attachment-1 ~ Attachment-11

*To explain each item in detail technically, eleven attachment materials appended separately.



Compartment between Main Text and Attachment Materials

● Main text

Although the technical specifications related to a core, fuel, heat transfer system, fuel handling system, instrumentation and control system, power supply, etc. are mentioned in the term of 5 in attachment material, they are only summaries.


● Attachment Materials

The detail technical specifications are explained in the attachment material of 6, 8 and 10 as the following.

- Attachment-6: **Environment, Climate** and **Earthquake**
- Attachment-8: **Safety Design** (**Basic Design**)
- Attachment-10: **Safety Evaluation**



Positioning of Attachment-6,-8 & -10 in Safety Assessment





Configuration of Attachment Materials

Attachment Materials

- 1) Explanation regarding “Purpose of Using Reactor”
- 2) Explanation regarding “Reactor Thermal Output”
- 3) Explanation regarding “Construction Fee and Financing Plan”
- 4) Explanation regarding “Acquisition Plan of Nuclear Fuel Materials”
- 5) Explanation regarding “Technical Capability” for Installation and Operation ”
- 6) Explanation regarding **Situations in Site such as Climate, Foundation, Hydrology, Earthquake, Social Environment**, etc.
- 7) Explanation regarding “Map of Site within 20km and 5km”
- 8) Explanation regarding **Safety Design** for **Basic Design**
- 9) Explanation regarding “Radiation Exposure Management and Disposing Method of Radioactive Waste”
- 10) Explanation regarding Evaluation **for Influence of Incident, Accident, Major and Hypothetical Accidents**
- 11) Explanation regarding “Financial Situation”



4. Contents of Attachment Materials

Attachment-6: Situations in Site such as Climate, Foundation, Hydrology, Earthquake, Social Environment (1/4)

1. Site

- 1.1 Conspectus of site
- 1.2 Overview of others

2. Climate

2.1 Climate of Tsuruga Area

- 2.1.1. Geographic features and climate
- 2.1.2. Climate of four seasons

2.2 Usual Climate based on the Materials of the Nearest Weather Office

- 2.2.1 Situation of the place of the weather office
- 2.2.2 The reason for having chosen the weather office in Fukui and Tsuruga
- 2.2.3 General climate conspectus in the nearest weather office

2.3 Climate Observation in the Site

- 2.3.1 Situation of observation points
- 2.3.2 Observation items
- 2.3.3 Qualification of climate observation equipments

2.4 Observation Results at the Site

2.5 Weather Conditions for applying to Safety Analysis

- 2.5.1 Study of representative climate data during climate observation period



Attachment-6: Situations in Site such as Climate, Foundation, Hydrology, Earthquake, Social Environment (2/4)

2.5 Weather Conditions for applying to Safety Analysis (Continuation)

- 2.5.2 Effective height of emission source applied to calculating atmospheric diffusion
- 2.5.3 Weather conditions applied to exposure evaluation in normal operation
- 2.5.4 weather conditions applied to exposure evaluation in assumption accident

3. Foundation

3.1 Process of Inspection

- 3.1.1 Survey of circumference of site area
- 3.1.2 Survey of neighboring of site area
- 3.1.3 Survey of reactor installation place

3.2 Geology/Geological Structure of Circumference of Site Area

- 3.2.1 Survey contents
- 3.2.2 Survey results

3.3 Geography/Geology/Geological Structure of Neighboring of Site Area

- 3.3.1 Survey contents
- 3.3.2 Survey result

3.4 Geology/Geological Structure and Foundation of Reactor Installation Place

- 3.4.1 Survey contents
- 3.4.2 Survey results
- 3.4.3 Evaluation of results
- 3.4.4 Verification regarding geology survey



Attachment-6: Situations in Site such as Climate, Foundation, Hydrology, Earthquake, Social Environment (3/4)

4. Hydrology

4.1 Inland Water

4.2 Oceanographic Phenomenon

4.2.1 Stream regime/flow speed

4.2.2 Tidal level

4.2.3 Ocean wave

4.2.4 Sea temperature

4.2.5 Drift sand

4.3 Water Utilization Plan

4.3.1 Necessary amount of water

4.3.2 Condenser cooling water and auxiliary cooling water

5. Earthquake

5.1 Past Earthquakes

5.1.1 Activity of earthquake

5.1.2 Earthquake damage history

5.1.3 Statistical expected value of Intensity of earthquake motion

5.2 Active Fault

5.2.1 Active faults to be considered as the strongest earthquake

5.2.2 Active faults to be considered as the limiting earthquake



Attachment-6: Situations in Site such as Climate, Foundation, Hydrology, Earthquake, Social Environment (4/4)

5. Earthquake (cont.)

5.3 Regional Geological Structure

5.4 Vibration Characteristic of Foundation

5.4.1 Earthquake observation

5.4.2 Regular microscopic observation

5.5 Standard Earthquake Vibration

5.5.1 Earthquakes which should be taken into consideration

5.5.2 Earthquake vibration characteristic

5.5.3 Standard earthquake vibration

6. Social Environment


6.1 Population Distribution

6.2 Neighboring Settlement and Public Facilities

6.3 Industrial Activities

6.4 Transportation System


6.5 Development Plan




Sample attachment figure: Geologic map around a site (Monju)



Sample attachment figure: Distribution map of active fault around a site (Monju)



Sample attachment figure: Seismic observation record at around a site (GL-46m)



Sample attachment figure: Response spectrum of standard earthquake motion (Monju)



Attachment-8: Explanation Regarding “Safety Design”

<Contents of Attachment-8> (1/25)

1. Safety Design

1.1 Safety Design Policy

1.1.1 Basic Policy of “Safety Design”

1.1.2 “Inherent Safety” of Reactor

1.1.3 Consideration on Safety in “Design and Manufacture of Reactor Plant Facilities”

1.1.4 Basic Policy of “Core Physics Design and Thermal Hydraulic Design”

(Sample Contents: Basic Policy of Core Physics Design)

- ✓ A core is hexagon pillar form of which a diameter ratio is 0.52, and consists of a total of 198 fuel assemblies and 172 blanket fuel assemblies of hexagon form and so on.
- ✓ A fuel region is divided into two parts of inner and outer sides, and the flat of power distribution is attained by rising the enrichment of an outer core.
- ✓ Reactivity control is carried out by using control rods.
- ✓ A reactor shutdown systems is composed of a main shutdown system which has both functions of reactivity control and emergency shutdown and a backup shutdown system for emergency shutdown.
- ✓ Even if one control rod cannot insert, a reactor should design so that a reactor can be scrammed safely by remained another control rods and has enough negative reactivity for maintaining a sub-criticality situation of a reactor.
- ✓ The maximum liner power density should be designed as less than 360w/cm so that fuel max. temperature never reach the melting point of a fuel pellet.
- ✓ A reactor should design so that a power coefficient becomes minus due to an negative feed back characteristic.



<Contents of Attachment-8> (2/25)

- 1.1.5 Preventive Measures of “Radioactive Material’s Diffusion”
- 1.1.6 Consideration on Design to “Sodium”
- 1.1.7 Basic Policy of “Instrumentation Control System’s Design”
- 1.1.8 Basic Policy of “Engineered Safety System”
- 1.1.9 Consideration on Design to “Removal of Decay Heat”
- 1.1.10 Consideration on Design to “Fire”
- 1.1.11 Consideration on Design to “Loss of Power”
- 1.1.12 “Physical Separation”
- 1.1.13 Basic Policy of “Intensity Design”
- 1.1.14 Basic Policy of “Quality Assurance”

(Sample Contents: **Quality Assurance**)

- ✓ Organization, work assignment and responsibility are clarified, and quality assurance (QA) activity performs certainly.
- ✓ To assure that the QA activity of a plant maker is carried out correctly, their organization, capability, manual, etc. has to be checked beforehand, and the investigation by Monju should be done if necessary.
- ✓ Also, the external order articles by a plant maker is treated as the same treatment.
- ✓ Each stage on determination of specification, design, manufacture, installation, test and inspection, the statute, standard, requirement to apply should be approved after confirming by documentation check or on-the-spot inspection whether basic design is satisfied or not.
- ✓ About documentations, figures, specifications, record of QA, etc., treatment method and management manual are clearly and is kept surely.



<Contents of Attachment-8> (3/25)

1.2 Design for Fitness to Safety Design Policy

1.2.1 Definition of term

1.2.2 “Application Regulations and Standards”

1.2.3 Design for Conformity regarding “Reactor and Instrumentation Control System”

1.2.4 Design for Conformity regarding “Reactor Shutdown System, Reactivity Control System and Reactor Protection System”

1.2.5 Design for Conformity regarding “Reactor Coolant System”

1.2.6 Design for Conformity regarding “Containment Vessel System”

1.2.7 Design for Conformity regarding “Fuel Handling System and Waste Disposing System”

1.2.8 Design for Conformity regarding “Radiation Protection and Radiation Control Facility”

(Sample of design for fitness < Policy-50: Critical Prevention of Nuclear Fuel>)

- ✓ A storage rack for storing of spent fuels should taken enough interval of each assembly, and should design so that an effective multiplication factor (k_{eff}) is kept less than 0.95 even if fuels are received to the limit of capacity
- ✓ Also, a storage rack should be design with earthquake proof class of A in order to not damage and to not close fuel assemblies each other.
- ✓ A fresh fuel storage rack should fully taken interval of each assembly and should store a fresh fuel under the inert gas.
- ✓ A fresh fuel storage rack should be made arrangement which is not flooded, and should be designed so that a k_{eff} can be maintained under 0.95 even if filling with a water.
- ✓ Fuel handling system has to handle only one assembly at each time operation, and is made the design which prevents criticality.
- ✓ Furthermore, it is made the design so that a reactor can be maintained sufficiently sub-criticality when a control rod is withdrawn during fuel handling work.



<Contents of Attachment-8> (4/25)

1.3 Seismic Design

- 1.3.1 “Basic Policy of Seismic Design”
- 1.3.2 “Importance Classification” on Seismic Design
- 1.3.3 Calculation Method of “Earthquake Load”
- 1.3.4 “Combine of Load” and “Allowable Limit”
- 1.3.5 “Seismic Structure” of Main Facilities

2. Plant Arrangement

2.1 Outline of Plant

2.2 Design Policy

2.3 Main Facilities

2.4 Whole Arrangement

2.5 Buildings and Structures

- 2.5.1 Outline
- 2.5.2 Reactor Building
- 2.5.3 Reactor Auxiliary Building
- 2.5.4 Turbine Building
- 2.5.5 Diesel Building
- 2.5.6 Maintenance and Waste Treatment Buildings
- 2.5.7 Switching Station
- 2.5.8 Solid Waste Storage Facility
- 2.5.9 Fresh Water Supply System
- 2.5.10 Drainage Treatment System
- 2.5.11 Argon and Nitrogen Supply System
- 2.5.12 Harbor System
- 2.5.13 Intake and Drain System





<Contents of Attachment-8> (5/25)

3. Reactor and Core

3.1 Outline

3.2 Mechanical Design

3.2.1 Fuel

3.2.2 Structures in Reactor Vessel

3.2.3 Reactivity Control System

3.3 Core Physics Design

3.3.1 Outline

3.3.2 Design Policy

Core design should be designed so that a reactor satisfies the following conditions during the life time.

(1) Shutdown Margin r Reactivity

- ✓ A reactor shutdown system should be a design which a reactor can be resulted in sub-criticality even if the control rod which has the maximum reactivity cannot be inserted due to its stick.
- ✓ Therefore, a main shutdown system should be designed have a shutdown margin reactivity of $0.01 \Delta k/k$ or more even if one control rod which has the maximum reactivity cannot be inserted.
- ✓ Moreover, even if it assumes that a main shutdown system doesn't work, a reactor should be maintained into sub-criticality under low temperature mode.

(2) Applying Ratio of Reactivity

- ✓ A maximum reactivity applying ratio should be made to less than $8 \times 10^{-5} \Delta k/k$ in order to prevent occurring a reactor core damage due to the reactivity accident assumed.



<Contents of Attachment-8> (6/25)

3.3.2 Design Policy

(3) Excess Reactivity

- ✓ An excess reactivity should be designed to compensate the following: reactivity change under from low temperature to the rated power operation mode; reactivity change by fuel burnup; operation margin.
- ✓ This excess reactivity should be designed to control by reactor shutdown system including a reactor margin reactivity shown in the term of (1).

(4) Power Coefficient

- ✓ A reactor should be designed to have a power coefficient which damps power fluctuation when a power level is changed.
- ✓ Accordingly, the Doppler coefficient is negative as a reactor has negative feedback characteristic, and the power coefficient integrating, not only the Doppler also including the temperature coefficient of fuel, structure, coolant and core support structure, should be designed to become minus under the all operation modes.

(5) Power Distribution

- ✓ The power distribution which exceeds a permissible design limit of fuel never happen under normal and abnormal operation conditions.
- ✓ The power distribution is made flat in order to take out thermal power effectively under a normal operation mode.
- ✓ Therefore, a reactor core is composed of two regions which is different plutonium enrichment, and the high plutonium enrichment fuels are loaded into outer core.
- ✓ The maximum linear power density under the rated power should be designed less than 360W/cm.



<Contents of Attachment-8> (7/25)

3.3.3 Analysis Method

Nuclear calculation is performed based on a multi-group neutron diffusion theory and a transport theory.

(1) Group Constant

- ✓ The group constant to be used is 26 group constant of ABBN type.
- ✓ This group constant consists of an infinite dilution cross-section, and the table of the self shielding factor of composition dependence and temperature dependence.
- ✓ An target energy range is from 10.5MeV to thermal energy range.

(2) Calculation of Power Distribution, Effective Multiplication Factor and Control Rod Worth

- ✓ Basic calculation is carried out by a diffusion calculation code.
- ✓ If needed, the nuclear characteristic amount is estimated by a transportation code and transportation theory compensation is performed.
- ✓ Calculation of fuel composition is obtained in consideration in three dimensional effect by combining RZ system and three angle mesh system.
- ✓ Power distribution, effective multiplication factor and control rod worth are calculated by RZ system and three angle mesh system

(3) Reactivity Coefficient

- ✓ The reactivity coefficient is got by two-dimensional diffusion perturbative calculation.

(4) Verification by Critical Experiment Analysis

- ✓ The group constant and design calculation method mentioned above are verified its reliability by critical experimental analysis such as FCA in Japan, ZPPR in USA.



<Contents of Attachment-8> (8/25)

3.3.4 Nuclear Design Value

- ✓ The design burnup of core fuel assembly is about 80,000MWD/t with average when taking out, while fuel pin maximum burnup is about 98,000MWD/t.
- ✓ The nuclear design values were calculated for all cores from an initial core to an equilibrium core.

3.3.5 Contents of Nuclear

3.3.5.1 Reactivity Control

- Reactivity control of a reactor is conducted by control rod.
- Control rod consists of regulation rods (main reactor shutdown system) and backup control rods (backup reactor shutdown system), moreover regulation rods are divided into fine control rods and coarse control rods.
- The usual start-up and shutdown operations are performed by regulation rods.
- Each reactor shutdown system has a function of emergency shutdown, respectively.
- Maximum excess reactivity of a reactor is about $0.057 \Delta k/k$ in the initial core and about $0.056 \Delta k/k$ in the equilibrium core.

(1) Reactor Shutdown System

- ✓ The reactor shutdown system has a function which can scram a reactor quickly and safely when a reactor is abnormal state.
- ✓ In case of necessary scram, a reactor should be able to be scrambled by the remained system even if one of the systems doesn't work.
- ✓ The reactor shutdown system has a reactor shutdown margin reactivity of $0.01 \Delta k/k$ or more at the lowest temperature on design (180°C).



<Contents of Attachment-8> (9/25)

3.3.5.1 Reactivity Control

(2) Regulation Rod

- ✓ A regulation rod has a function which controls the required reactivity for operating.
- ✓ A regulation rod is composed of the fine control rods and the coarse control rods, and a reactivity applying curve of regulation rod is shown in figure.

1) Fine Control Rod

- a). A fine control rod mainly controls the reactivity change causing by fuel temperature, structure and coolant temperature's change due to reactor power change.
- b). A fine control rod has an enough control rod worth which can control a reactor without scram when a loading set value is changed with ramp change of $\pm 5\%/min$, or step change of 10%.
- c). The maximum reactivity applying ratio by withdrawing a regulation rod is decided with reactivity applying curve and max. driving speed. The max. driving speed is less than 0.3m/min, and the max. reactivity applying ratio is under $8 \times 10^{-5} \Delta k/k$.
- d) Two fine control rod cannot be withdrawn simultaneously.
- e) During the rated power operation, three fine control rods are adjusted so that they are in the fixed range in consideration of load following operation.

2) Coarse Control Rod

- a). A coarse control rod mainly controls the reactivity change causing by fuel temperature, structure and coolant temperature's change due to startup operation from reactor stop state to about 30% power operation.
- b). The max. driving speed of a coarse control rod is less than 0.12m/min, and the max. reactivity applying ratio is under $4 \times 10^{-5} \Delta k/k$.
- c). Two fine control rod cannot be withdrawn simultaneously as well as fine control rod.



<Contents of Attachment-8> (10/25)

3.3.5.1 Reactivity Control

(3) Backup Control Rod

- ✓ A backup control rod should be able to scram a reactor under all operation modes promptly when emergency scram is needed and can maintain sub-criticality state with sufficient predetermined reactor shutdown margin reactivity.
- ✓ The backup control rods are always kept with the position of withdrawing completely from a core.

3.3.5.2 Required Reactivity and Functional Assignment of Control Rod

(1) Required Reactivity

A control rod should control reactivity is as follows: (Required reactivity)

1) Power Compensation

The reactivity change during from reactor shutdown state (180°C) to the rated power state is compensated.

2) Burnup Compensation

The reactivity change accompanying fuel handling in each fuel cycle is compensated by a coarse control rod.

3) Error Cancellation of Reactor Reactivity

An error between the reactor reactivity and the reserve value of reactivity is canceled.

4) Operation Margin

A fine control rod has the necessary reactivity for operation and is inserted to the position where is assure the required differential reactivity worth for load following operation.



<Contents of Attachment-8> (11/25)

3.3.5.2 Required Reactivity and Functional Assignment of Control Rod

5) Reactivity Shutdown Margin

The reactor shutdown system has the predetermined reactivity shutdown margin respectively so that a reactor can be stopped during all operation modes and can be kept sufficient sub-criticality.

6) Functional Assignment of Control Rod

With respect to the reactivity which should be controlled by each control rod, the functional assignment is described in the table.

3.3.5.3 Reactivity Coefficient

- A reactivity coefficient is a coefficient showing reactivity change due to the change of fuel temperature, structural material temp. and coolant temp., etc. and is shown in the table.
- The Doppler coefficient is a ratio of reactivity change due to change of fuel effective temperature, and is negative in Monju which uses MOX fuel.
- The Doppler coefficient is dominant in the effect of reactivity change for the change of various reactor plant parameters.
- Therefore, a power coefficient integrated those is always maintained in the all operation modes and gives inherent safety to a reactor.
- Although a void factor in Monju due to boil of a coolant is positive, its value assumed in a design against boiling of one fuel assembly which has maximum reactivity, is smaller compared with the Doppler coefficient and the core support plate coefficient as shown in the table.



<Contents of Attachment-8> (12/25)

3.3.5.4 Power Distribution

In order to be flat power distribution of a reactor, the following items are taken into account.

- 1) A reactor core region is divided into two regions of an inner core and an outer core with the almost same volume.
- 2) Flat of power distribution is achieved by loading the fuel assemblies of the high plutonium enrichment into an outer core.
- 3) Fuel handling method adopts the distributed form.
- 4) The fine and coarse control rods should be operated so that it may not become unusual power distribution.
- 5) An output assignment ratio changes following fuel burnup, and an output assignment ration of blanket fuel region tends increasing due to accumulation of plutonium in there. An output assignment in each region is shown in the table.

3.3.5.5 Stability

- An output coefficient is negative during all operation modes because coefficients of Doppler and fuel temperature are bigger compared with other coefficients, and a reactor has self-regulating characteristics against power fluctuation.
- Also, neutron flux distribution in a core is not largely distorted locally when control rods are inserted, and power distribution is stable since spatial vibration of neutron flux distribution does not happen because fission products does not have a big absorption cross section within the neutron energy regions.



<System Specifications of Reactor Core>

原子炉熱出力		714 MW
1次冷却材流量		約 15.3×10^6 kg/h
1次冷却材入口温度		約 397 °C
1次冷却材出口温度		約 529 °C
炉心燃料領域形状		
領域数		2
有効高さ		約 0.93 m
等価直径		約 1.8 m
軸方向ブランケット厚さ	上部	約 0.3 m
	下部	約 0.35 m
半径方向ブランケット等価厚さ		約 0.3 m
初装荷燃料装荷量		
炉心燃料領域	プルトニウム及びウラン	約 5.9 t
軸方向ブランケット	ウラン	約 4.5 t
半径方向ブランケット	ウラン	約 13 t
炉心燃料集合体数		
内側炉心		108 体
外側炉心		90 体
ブランケット燃料集合体数		172 体
制御棒集合体数		19 体
中性子源集合体数		2 体
中性子しゃへい体数		316 体
サーベイランス集合体数	中性子しゃへい体領域装荷	8 体
	炉内ラック装荷	最大 8 体
炉心燃料平均取出し燃焼度		約 80,000 MWD/T
増殖比		約 1.2
炉心燃料領域組成比	燃料	約 33.5 vol %
	冷却材	約 40.0 vol %
	構造材	約 24.5 vol %
	空隙	約 2.0 vol %

(関連頁 8-3-1)

<Design Specifications of Fuel Assembly>

(i) 炉心燃料集合体		
(i) 燃料		
炉心燃料材料		プルトニウム・ウラン混合酸化物
核分裂性プルトニウム富化度		
初装荷燃料		約 15 wt % (内側炉心領域)
		約 20 wt % (外側炉心領域)
取替え燃料		約 16 wt % (内側炉心領域)
		約 21 wt % (外側炉心領域)
ウラン 235 含有率		約 0.3 wt %
ペレット密度		約 85 % 理論密度
軸方向ブランケット燃料材料		二酸化ウラン
ウラン 235 含有率		約 0.3 wt %
ペレット密度		約 93 % 理論密度
ペレット直径		約 5.4 mm
ペレット長さ		約 8 mm (炉心燃料)
		約 10 mm (軸方向ブランケット燃料)
燃焼度		
初装荷炉心平均		約 16,000 MWD/T
平衡炉心平均		約 80,000 MWD/T
燃料集合体最高		約 94,000 MWD/T
燃料要素最高		約 98,000 MWD/T
ペレット最高		約 130,000 MWD/T
ペレット最高温度		
定格出力時		約 2,350 °C
最大線出力密度時 (過出力時)		約 2,600 °C
(ii) 被ふく管		
材料		SUS316 相当ステンレス鋼
外径		約 6.5 mm



<Core Design Specifications>

燃料交換法

炉心燃料集合体

5 バッチ分散方式

ブランケット燃料集合体

5 バッチ分散方式

核分裂性プルトニウム富化度

初装荷燃料 (内側炉心, 外側炉心)

約 15wt %, 約 20wt %

取替え燃料 (内側炉心, 外側炉心)

約 16wt %, 約 21wt %

増殖比

初装荷炉心

約 1.2

平衡炉心

約 1.2

炉心燃料平均取出し燃焼度

初装荷炉心

約 16,000 MWD/T

平衡炉心

約 80,000 MWD/T

線出力密度

定格出力時炉心平均

約 210W/cm

定格出力時炉心最高

約 360W/cm

制御棒価値

調整棒 (最大価値調整棒 1 本未そう入時)

初装荷炉心 平衡炉心
約 0.07Δk/k 約 0.07Δk/k

後備炉停止棒

約 0.06Δk/k 約 0.06Δk/k

反応度係数

ドッブラ係数

$$-(5.7 \sim 7.6) \times 10^{-3} T \frac{dk}{dT}$$

燃料温度係数

$$-(3.3 \sim 3.9) \times 10^{-6} \Delta k/k/^\circ C$$

構造材温度係数

$$+(6.0 \sim 1.0) \times 10^{-7} \Delta k/k/^\circ C$$

冷却材温度係数

$$+(1.0 \sim 1.4) \times 10^{-7} \Delta k/k/^\circ C$$

炉心支持板温度係数

$$-(1.0 \sim 1.2) \times 10^{-6} \Delta k/k/^\circ C$$

出力係数

$$-(9.4 \sim 1.1) \times 10^{-6} \Delta k/k/MW$$

1 炉心燃料集合体最大キッド反応度

$$+(1.1 \sim 1.5) \times 10^{-4} \Delta k/k$$

即発中性子寿命

0.40~0.45 μs


実効遅発中性子割合

0.0034~0.0038


<Reactivity Balance>

炉心 原子炉停止系 制御棒		×10 ⁻² Δk/k			
		初装荷炉心		平衡炉心	
		主炉停止系 調整棒	後備炉停止系 後備炉停止棒	主炉停止系 調整棒	後備炉停止系 後備炉停止棒
反応度バランス					
所要反応度	出力補償	1.9	1.9	1.7	1.7
	燃焼補償	2.5	—	2.6	—
	運転余裕	0.3	—	0.3	—
	炉の反応度の誤差吸収	1.0	—	1.0	—
	所要反応度の合計	5.7	1.9	5.6	1.7
制御棒価値		7.1*	5.9	7.0*	5.8
余裕反応度		1.4	4.0	1.4	4.1

* 最大反応度価値を持つ制御棒 1 本が、全引抜き位置のままそう入できないとした場合。




<Internal Structure of Reactor Core>




炉心構成要素		記号	数量
炉心燃料集合体	内側炉心	⊙	108
	外側炉心	⊗	90
ブラケット燃料集合体		⊛	172
制御棒集合体	微調整棒	⊕	3
	粗調整棒	⊖	10
	後備炉停止棒	⊗	6
中性子源集合体	⊕	2	
中性子しゃへい体	○	316	
サーベイランス集合体	⊕	8	


<Core Map of Initial Core>




<Structure of Fuel Assembly >



<Structure of Blanket Assembly >



<Analysis of Power Up with
5%/min lump Ration>



<Analysis of Power Down with
5%/min lump Ration>



3.3.5.6 Fuel Handling and Change following Burnup

- Fuel handling method adopts five batch dispersion method, i.e., one fifth of each core (inner, outer and blanket) is exchanged with the interval of each half years.
- The duration of one fuel cycle is about 148 EFPD (effective full power day).
- In addition, fuel handling in the early stage of formal operation will be performed with four batch dispersion method with accumulating the irradiation results. That time's duration of one fuel cycle is about 123 EFPD.
- During the period mentioned above, change of power distribution and nuclear characteristics value are little.

3.4 Thermal Hydraulic Design

3.4.1 Outline

3.4.2 Design Policy

3.4.3 Analysis Method

3.4.4 Thermal Hydraulic Design Values

3.4.5 Contents of Thermal Hydraulic Design

3.4.5.1 Power distribution applied to thermal hydraulic design

3.4.5.2 Coolant flow distribution

3.4.5.3 Maximum temperatures of coolant and fuel cladding

3.4.5.4 Fuel maximum temperature





<Contents of Attachment-8> (14/25)

3.5 Dynamic Analysis

- 3.5.1 Outline
- 3.5.2 Design Policy
- 3.5.3 Analysis Method
- 3.5.4 Transient Response
- 3.5.5 Assessment

4. Primary Cooling System

4.1 Outline

4.2 Design Policy

4.3 Specifications of Main Components

4.4 Main Components

- 4.4.1 Reactor Vessel
- 4.4.2 Shielding Plug
- 4.4.3 Primary Main Circulation pump
- 4.4.4 Primary Main Intermediate Heat Exchanger (IHX)
- 4.4.5 Primary Main Piping
- 4.4.6 Valves
- 4.4.7 Guard Vessel
- 4.4.8 Support Structures
- 4.4.9 Sodium Leak Detector System
- 4.4.10 Pre-heating and Thermal Insulator Systems





<Contents of Attachment-8> (15/25)

4.5 Test, Inspection

- 4.5.1 Reactor Vessel
- 4.5.2 Primary Main Circulation Pump
- 4.5.3 Primary Main Heat Exchanger
- 4.5.4 Primary Main Cooling Piping

5. Secondary Main Cooling System

5.1 Outline

5.2 Design Policy

5.3 Specifications of Main Components

5.4 Main Components

- 5.4.1 Secondary Main Circulation Pump
- 5.4.2 Steam Generator
- 5.4.3 Secondary Main Cooling Piping
- 5.4.4 Valves
- 5.4.5 Support Structures
- 5.4.6 Sodium Leak Detector System
- 5.4.7 Pre-heating and Thermal Insulator Systems



<Contents of Attachment-8> (16/25)

6. Auxiliary Cooling System

6.1 Outline

6.2 Design Policy

6.3 Specifications of Main Components

6.4 Main Components

6.4.1 Auxiliary Dump Heat Exchanger

6.4.2 Auxiliary Cooling Piping

6.4.3 Valves

6.4.4 Support Structures

6.4.5 Sodium Leak Detector System

6.4.6 Pre-heating and Thermal Insulator Systems

6.5 Assessment

6.6 Test, Inspection

7. Engineered Safety System

7.1 Outline

7.2 Reactor Containment Facility

7.2.1 Outline

7.2.2 Design Policy

7.2.3 Specifications of Main Components

7.2.4 Main Components

7.2.5 Assessment

7.2.6 Test, Inspection





<Contents of Attachment-8> (17/25)

7.3 Annulus Circulation Exhaust Equipment


- 7.3.1 Outline
- 7.3.2 Design Policy
- 7.3.3 Specifications of Main Components
- 7.3.4 Main Components
- 7.3.5 Assessment
- 7.3.6 Test, Inspection

7.4 Guard Vessel


- 7.4.1 Outline
- 7.4.2 Design Policy
- 7.4.3 Main Components
- 7.4.4 Assessment
- 7.4.5 Test, Inspection

7.5 Auxiliary Cooling System

- 7.5.1 Outline
- 7.5.2 Design Policy
- 7.5.3 System Design and Main Components
- 7.5.4 Assessment
- 7.5.5 Test, Inspection




<Main Cooling System>




NsL : 原子炉容器通常冷却材液位
 SsL : システム・レベル
 = NsL - 約 3 m
 EsL : エマージェンシ・レベル
 = NsL - 約 4 m


<Guard Vessel for Primary Main Cooling System>




<Structure of Primary Main IHX>



<Structure of Primary Main Pump>



<Structure of Evaporator>



<Structure of Super-Heater>



<Contents of Attachment-8> (18/25)

7.6 Primary Argon Gas Containment System

- 7.6.1 Outline
- 7.6.2 Design Policy
- 7.6.3 Main Components
- 7.6.4 Assessment
- 7.6.5 Test, Inspection

8. Reactor Auxiliary System

8.1 Outline

8.2 Sodium Auxiliary System

- 8.2.1 Primary Sodium Auxiliary System
- 8.2.2 Maintenance Cooling System
- 8.2.3 Secondary Sodium Auxiliary System

8.3 Argon Gas System

- 8.3.1 Primary Argon Gas System
- 8.3.2 Secondary Argon Gas System

8.4 Reactor Auxiliary Component Cooling System

- 8.4.1 Outline
- 8.4.2 Design Policy
- 8.4.3 Specifications of Main Components
- 8.4.4 Main Components





<Contents of Attachment-8> (19/25)

8.5 Fuel Handling and Storage System

- 8.5.1 Outline
- 8.5.2 Design Policy
- 8.5.3 Specifications of Main Components
- 8.5.4 Main Components
- 8.5.5 Test, Installation

9. Instrumentation Control System

9.1 Outline

9.2 Reactor Instrumentation System

- 9.2.1 Outline
- 9.2.2 Neutron Instrumentation
- 9.2.3 Instrumentation in Reactor Vessel
- 9.2.4 Fuel Failure Detection System
- 9.2.5 Instrumentation of Control Rod Position Indication

9.3 Process Instrumentation

- 9.3.1 Outline
- 9.3.2 Design Policy
- 9.3.3 Main Equipments
- 9.3.4 Assessment



<Contents of Attachment-8> (20/25)

9.4 Reactor Control System

- 9.4.1 Outline
- 9.4.2 Design Policy
- 9.4.3 Main Equipments
- 9.4.4 Assessment

9.5 Reactor Protection System


- 9.5.1 Outline
- 9.5.2 Design Policy
- 9.5.3 Main Equipments
- 9.5.4 Assessment

9.6 Activation System of Engineered Safety System


- 9.6.1 Outline
- 9.6.2 Design Policy
- 9.6.3 Main Equipments
- 9.6.4 Assessment

9.7 Control Room


- 9.7.1 Outline
- 9.7.2 Center Control Room
- 9.7.3 Extra Reactor Shutdown System located in outside of Center Control Room




<Bird-View of Fuel Handling System>




<Primary Argon Gas System>



<Secondary Argon Gas System>



<Reactor Control System>



<Reactor Power Control System>




原子カトリップ信号	検出器	作動ロジック	インタロック
線源領域中性子束高	線源領域中性子束検出器	1 / 2	(P-A)設定値以上で手動ブロック
広域中性子束高	広域中性子束検出器	2 / 3	(P-B)設定値以上で手動ブロック
出力領域中性子束高	出力領域中性子束検出器	2 / 3	(P-B)設定値以上で手動ブロック
出力領域中性子束変化率高	出力領域中性子束検出器	2 / 3	(P-A)設定値以下で手動ブロック
原子炉容器ナトリウム液位低	原子炉容器ナトリウム液面計	2 / 3	(P-A)設定値以下で手動ブロック
原子炉容器出口ナトリウム温度高	原子炉容器出口ナトリウム温度検出器	各グループ2 / 3	
中間熱交換器1次側出口ナトリウム温度高	中間熱交換器1次側出口ナトリウム温度検出器	各グループ2 / 3	
1次主冷却系循環ポンプ回転数低	(1次主冷却系循環ポンプ)回転数検出器 出力領域中性子束検出器	各グループ2 / 3	(P-A)設定値以下で手動ブロック
1次主冷却系循環ポンプ回転数高	(1次主冷却系循環ポンプ)回転数検出器 出力領域中性子束検出器	各グループ2 / 3	
1次主冷却系流量低	(1次主冷却系流量検出器) 広域中性子束検出器	各グループ2 / 3	(P-A)設定値以下で手動ブロック
2次主冷却系循環ポンプ回転数低	(2次主冷却系循環ポンプ)回転数検出器 出力領域中性子束検出器	各グループ2 / 3	(P-A)設定値以下で手動ブロック
2次主冷却系流量低	(2次主冷却系流量検出器) 広域中性子束検出器	各グループ2 / 3	(P-A)設定値以下で手動ブロック
蒸発器出口ナトリウム温度高	蒸発器出口ナトリウム温度検出器	各グループ2 / 3	
タービントリップ	主蒸気止弁弁位置検出器	2台閉	(P-C)設定値以下で自動ブロック
常用母線電圧低	常用母線電圧低電圧リレー	各母線 2 / 3	
燃料破損検出	遅発中性子束検出器	各グループ2 / 3	
原子炉格納容器隔離			第 9.6 - 1 表(O)
地震加速度大			
a 水平方向加速度	水平方向加速度検出器	2 / 3	
b 垂直方向加速度	垂直方向加速度検出器	2 / 3	
手動		1 / 2	

出 トリップ設定値は詳細設計で決定

(関連頁 8 - 9 - 2 4)

<List of Reactor Scram Items>



<Reactor Safety Protection System Flow>



<Contents of Attachment-8> (21/25)

10. Electric System

10.1 Outline

10.2 Design Policy

10.3 Main Equipments

10.3.1 Power Line

10.3.2 Special High Voltage Switching Station

10.3.3 Generator and Magnetization Machine

10.3.4 Main Transformer

10.3.5 High Voltage Line in Station

10.3.6 Low Voltage Line in Station

10.3.7 Diesel Generator

10.3.8 Battery and Uninterruptible Power Source

10.3.9 Power Supply System for Control Rod Holding Magnet

10.3.10 Electric Wire Route

10.4 Switching Power Line During Accident


10.5 Test and Inspection for Emergency Power Supply System

11. Turbine and Attached System


11.1 Outline

11.2 Design Policy







<Power Supply Switching Line>



<Power Supply Line>



<DC Power Line>



<AC Uninterruptible Power Line>



<Contents of Attachment-8> (22/25)

11.3 Main Equipments

- 11.3.1 Main Steam System
- 11.3.2 Steam Turbine System
- 11.3.3 Condenser System
- 11.3.4 Water Supply System
- 11.3.5 Pump Bearing Cooling Water System

12. Radioactive Waste Disposal Facility

12.1 Outline

12.2 Gas Waste Treatment System

- 12.2.1 Outline
- 12.2.2 Design Policy
- 12.2.3 Main System

12.3 Liquid Waste Treatment System

- 12.3.1 Outline
- 12.3.2 Design Policy
- 12.3.3 Main System

12.4 Solid Waste Treatment System

- 12.3.1 Outline
- 12.3.2 Design Policy
- 12.3.3 Main System





<Contents of Attachment-8> (23/25)

13. Radiation Control Facility

13.1 Shielding System

- 13.1.1 Outline
- 13.1.2 Design Policy
- 13.1.3 Main System
- 13.1.4 Assessment

13.2 Radiation Control System

- 13.2.1 Outline
- 13.2.2 Design Policy
- 13.2.3 Main System
- 13.2.4 Assessment

14. Auxiliary System

14.1 Fresh Water Supply System


- 14.1.1 Outline
- 14.1.2 Main System

14.2 Ventilation Air Conditioning System


- 14.2.1 Outline
- 14.2.2 Design Policy
- 14.2.3 Main System




〔気体廃棄物処理設備〕




〔液体廃棄物処理設備〕



〔固体廃棄物処理設備〕



<Radioactive Waste Disposal System



<Charcoal Absorption System>



<Contents of Attachment-8> (24/25)

14.3 Compressed Air Supply System

14.3.1 Compressed Air Supply System for Control

14.3.2 Compressed Air Supply System for Inside of Station

14.4 Gas Supply System

14.4.1 Argon Gas Supply System

14.4.2 Nitrogen Gas Supply System

14.5 Auxiliary Steam Supply System

14.5.1 Outline

14.5.2 Design Policy

14.5.3 Main System

14.6 Extinguish System

14.6.1 Outline

14.6.2 Design Policy

14.6.2 Main System

14.7 Drainage Treatment System

14.7.1 Outline

14.7.2 Main System

14.8 Sodium Supply System

14.8.1 Outline

14.8.2 Design Policy

14.8.3 Main System



<Contents of Attachment-8> (25/25)

15. Operation and Maintenance

15.1 Basic Policy of Operation/Maintenance

15.2 Organization and Job

15.3 Operation Management

15.4 Fuel Management

15.5 Radioactive Waste Management

15.6 Radiation Control

15.7 Maintenance

15.8 Measures for Emergency

15.9 Education and Training

15.10 Health Management

15.11 Security Management for Staffs

15.12 Record and Report





Attachment-10: Explanation Regarding “???????”

Since Attachment-10 is mentioned in the “Safety Assessment of Reactor Plant” of Lecture-??” in detail, its contents is skipped in here.



5. Actual Example of Installation Permission of NPP

As an actual example, Change of Application of Installation Permission of Tomari and Onagawa NPP Accompanying introduction of Plutonium Fuel is mentioned in the following.


By introducing Plutonium Fuel, change the following items:

- 1) Fall of Melting Point and Thermal Conductivity of Fuel Pellet
- 2) Increase of Fission Product (FP) Gas Emission
- 3) Change of Power Distribution in Radial Direction
- 4) Fall of Rod Worth (Decrease of Boron Effect)
- 5) Change of Nuclear Characteristics (Increase of Fission Cross Section, Thermal Absorption Cross Section, Temperature Effect and Fall of Delayed Neutron Yield, etc.)
- .
- .
- .





Main Screening Contents of Safety Assessment





Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant

1.1 Reactor Core

(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)

1.2 Emergency Core Cooling System (ECCS)

1.3 Fuel Storage Facility

2. exposure Evaluation of General Public around NPP

3. Analysis of Abnormal Transient Change (Incident) during Normal Operation

4. Analysis of Accident

5. Analysis of Hypothetical Accident for Siting Evaluation

6. Technical Capability



1.1 (1) Reactor Core (Mechanical Design)

Screening Points for Soundness Assessment of Fuel Assembly

1) Central Max. Temp. of Fuel Pellet

- ☞ The possibility of **Melt of Fuel Pellet due to Abnormal High Temperature** (Comparison with Criterion)

2) Inner Pressure of Fuel Pin

- ☞ The possibility of **Rapture of Fuel Pin due to FP Gas Expansion** (Comparison with Criterion)

3) Thermal Stress of Fuel Cladding Tube


- ☞ **Thermal Stress of Fuel Cladding Tube due to Thermal Loading (During in Normal operation, Incident and Accident)** (Comparison with Criterion)

4) Tensile Strain of Fuel Cladding Tube

- ☞ **Axial Thermal Stress of Fuel Cladding Tube due to Thermal Loading** (Comparison with Criterion)

5) Cumulative Fatigue of Fuel Cladding Tube

- ☞ **Cumulative Fatigue Damage Coefficient of Fuel Cladding Tube due to Repeat Thermal Loading** (Comparison with Criterion)






Example of Analysis Results (1)*: **Central Max. Temp. of Fuel Pellet (1/2)**


<Screening Point>

Isn't a fuel melted when reactor's temperature is risen to abnormal high temp.?





Example of Analysis Results (1)*: **Central Max. Temp. of Fuel Pellet (2/2)**






Example of Analysis Results (2)*: **Inner Pressure of Fuel Pin**

*Tomari NPP (PWR): 912Mwe

<Screening Point>

Isn't a fuel pin damaged by unusual expansion due to the filling fission products (FP) gas within a pin?



Pellet Mechanical Characteristic

Inner Pressure Increasing by Expanding FP Gas

*1: Since a Fuel pin receives high pressure from outside, helium gas is filled within a pin in order to prevent being crushed.

Counter Measure

Adjusting the gas quantity enclosing within a pin (helium gas)*1 adequately

Analysis of Inner Pressure within a Pin

Analysis Results

*2: Criterion of Judgment ≤ 1.0

- ◆ Uranium Fuel: 0.73 (Contrast with Design)*2
- ◆ MOX Fuel: 0.80 (Contrast with Design)*2





Example of Analysis Results (3): **Thermal Stresses of Fuel Cladding Tube**

<Screening Point>

Isn't a fuel cladding tube damaged by thermal stress due to the unusual rising up of reactor power?

*1: Onagawa NPP (BWR): 825Mwe



Analysis Results

*2: Criterion of Judgment ≤ 1.0

- ◆ Uranium Fuel: 0.75 (Contrast with Design)*2
- ◆ MOX Fuel: 0.84 (Contrast with Design)*2



Example of Analysis Results (4)*: **Summarization of Mechanical Design of Fuel Assembly**

(Representative Example)

Assessment Items		Uranium Fuel		MOX Fuel	
		Calculated Value	Criterion of Judgment	Calculated Value	Criterion of Judgment
Central Max. Temp. of Fuel Pellet	Rated Power	at. 1,740°C	<2,580°C	at. 1,740°C	<2,500°C
	Abnormal Operation	at. 2,220°C		at. 2,230°C	
Inner Pressure of Fuel Pin		0.73	≤ 1.0	0.80	≤ 1.0
Thermal Stress of Fuel Cladding Tube		0.75	≤ 1.0	0.84	≤ 1.0
Tensile Strain of Fuel Cladding Tube		0.36%	$\leq 1.0\%$	0.42%	$\leq 1.0\%$
Cumulative Fatigue of Fuel Cladding Tube		0.18	≤ 1.0	0.13	≤ 1.0

*Tomari NPP (PWR): 2,660MWt (912Mwe)




1.1 (2) Reactor Core (Nuclear Design)

Main Important Design Points on Core Design

- ◆ Even if a control rod which has **Maximum Rod Worth (reactivity) cannot insert** from the whole withdrawing position, a reactor can be maintained in the state of **Sub-Criticality**^{*1} under high temperature condition by remained control rods.
(*1: **Reactor Shutdown Margin Reactivity >1.8%Δk/k**)
- ◆ Moreover, a core can be kept in the state of sub-criticality under low temperature condition by **Chemical Control System** (Boric Acid).
(*2: Reactor Shutdown Margin Reactivity >1.0%Δk/k)
- ◆ A core should be designed so that **Doppler Effect** and **Moderator Temperature Effect become negative** and has the inherent rapid power control effect.



Reference: Reactor Shutdown Margin



<Excess Reactivity>

The Excess Reactivity decreases accompanying with operation due to the following reasons:

- 1) Core Conversion Ratio is small, especially in LWR. (at 0.6)
- 2) Poison FP ($^{135}\text{Xe}, ^{149}\text{Sm}$) increases accompanying with operation

<Reactor Shutdown Margin at Rated Power> (% $\Delta k/k$)

	CR Worth	ρ_E	ρ_M
PWR	at 31%	29%	1.8%
BWR	at 27%	25%	at 2.0%
FBR	7%	5.6%	1.4%






Example of Analysis Results (1): **Reactor Shutdown Margin Reactivity**

<Screening Point>

Does a core have enough reactor shutdown capability (Reactor Shutdown Margin Reactivity)?



Assess whether a core can be shutdown with having margin safely






Example of Analysis Results (2): Self Regulating Characteristics (1/2)

<Screening Point>

When a reactor power is fluctuated rapidly, can a core be returned to a stable state by self regulating characteristics of Doppler Effect and Moderator Temperature Effect?

Assess whether a core can be stabilized quickly against rapid power fluctuation



The Self Regulating Characteristics of MOX fuel core is stronger than uranium fuel core one.

Power Fluctuation

Power Fluctuation

$\times 10^{-5} (\Delta k/k/^\circ C)$

Item	Uranium Fuel Core	MOX Fuel Core
Doppler Coe.	-3.5 ~ -2.4	-3.6 ~ -2.6
Moderator Temp. Coe.	-66 ~ -7.9	-71 ~ -11.5


*Tomari NPP (PWR)



Example of Analysis Results (2)*: **Self Regulating Characteristics (2/2)**

*Onagawa NPP (BWR): 825Mwe

(Analysis Result of Reactor Power Change When Cutting Off of Generator Loading)





1.1 (3) Reactor Core (Thermal-Hydraulic Design)


Most Important Design Point on Thermal-Hydraulic Design

- ◆ The most important point on thermal-hydraulic design is to prevent occurring of “**Boiling Transition**”.
- ◆ Boiling Transition is the phenomenon moving from **Nucleate Boiling** with good heat transfer to bad **Film Boiling**.
- ◆ Whether Boiling Transition occurs or not is judged by the value of “**Departure from Nucleate Boiling Ratio**” (**DNBR**).
- ◆ Thermal-hydraulic design of a core should be designed so that Minimum DNBR at rated power becomes bigger than Allowable Limit DNBR.
- ◆ DNBR is given as he following:

$$\text{DNBR} = \frac{\left[\text{Heat Flux when fuel cladding tube's temperature begins rising up rapidly causing by heat transfer between cladding and coolant falls} \right]}{\left[\text{Actual Heat Flux} \right]}$$



Boiling Curve and Analysis Result of DNBR





Q: Heat Flux at Heating Plane
 Tw: Temp. at Heating Plane
 Ts: Saturation Temp.

(Analysis Results)

👉 Min. DNBR=2.15
 > Allowable Limit DNBR=1.42

*Tomari NPP (PWR):
 2,660MWt (912Mwe)





Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant

1.1 Reactor Core

(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)

1.2 Emergency Core Cooling System (ECCS)

1.3 Fuel Storage Facility

2. Exposure Evaluation of General Public around NPP

3. Analysis of Abnormal Transient Change (Incident) during Normal Operation

4. Analysis of Accident

5. Analysis of Hypothetical Accident for Siting Evaluation

6. Technical Capability




1.2 Emergency Core Cooling System (ECCS)

<Screening Point>


- ◆ ECCS should be a design which can prevent a serious damage of fuel for the accident of loss of coolant and moreover can restrict a reaction between fuel cladding metal and a water to a small quantity sufficiently
 - ◆ ECCS should have redundancy or diversity and independency in order to perform its safety function completely even if an external power cannot be used in addition to assumption of the single failure of an equipment.
 - ◆ ECCS should be a design which can conduct test and inspection periodically and can carry out test and inspection of each system independently for assuring its soundness and redundancy.
- ✚(Reference: For MOX Fuel Core)
- ◆ Since **Reactivity Worth of Boric Acid Solution** is fallen by using plutonium, its concentration has to be increased.
 - ☞ Example: From **3,000ppm** to \geq **3,200ppm** at Tomari NPP



Emergency Core Cooling System (ECCS) in BWR and PWR



<ECCS in BWR>



<ECCS in PWR>





Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant

1.1 Reactor Core

(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)

1.2 Emergency Core Cooling System (ECCS)

1.3 Fuel Storage Facility

2. Exposure Evaluation of General Public around NPP

3. Analysis of Abnormal Transient Change (Incident) during Normal Operation

4. Analysis of Accident

5. Analysis of Hypothetical Accident for Siting Evaluation

6. Technical Capability




Example of Analysis Results*: **Fuel Storage of MOX Fuel**


<Screening Point>

Can Decay Heat of MOX Fuel stored in spent fuel storage pool be removed safely?

Decay Heat of MOX Fuel is larger than Uranium Fuel




Analysis of Pool Temp. in the Most Severe Condition (A Pool is altogether occupied with MOX Fuels.)



It was confirmed that MOX Fuel can be stored safely.

*Onagawa NPP (BWR): 825Mwe



	Water Temp. of Pool	Standard Value
Storage of MOX Fuel	at 54°C	65°C



Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant
 - 1.1 Reactor Core
(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)
 - 1.2 Emergency Core Cooling System (ECCS)
 - 1.3 Fuel Storage Facility
- 2. Exposure Evaluation of General Public around NPP**
3. Analysis of Abnormal Transient Change (Incident) during Normal Operation
4. Analysis of Accident
5. Analysis of Hypothetical Accident for Siting Evaluation
6. Technical Capability




Dose Evaluation of General Public around NPP under Normal Operation

Screening Item

- 1) Confirmation that the Dose which the General Public receives under normal operation can fully be less than the **Allowable Dose defined by law**. ($\leq 1\text{mSv per year}$)
- 2) Confirmation that the Dose Evaluation Value can be less than the **Dose Target Value***. ($\leq 50\mu\text{Sv per year}$)

*Dose Target Value is defined in order to reduce rationally the dose general public receiving as much as possible.



<Sample Evaluation Result>

It was confirmed that Tomari NPP is designed that the following both values can be satisfied:

- ◆ Allowable Dose at Out of Circumference Observing Sector defined by Law is sufficiently less than 1mSv/year.



Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant
 - 1.1 Reactor Core
(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)
 - 1.2 Emergency Core Cooling System (ECCS)
 - 1.3 Fuel Storage Facility
2. Exposure Evaluation of General Public around NPP
- 3. Analysis of Abnormal Transient Change (Incident) during Normal Operation**
4. Analysis of Accident
5. Analysis of Hypothetical Accident for Siting Evaluation
6. Technical Capability



Analysis Events for Incident Evaluation

(1) Abnormal Change of Reactivity or Power Distribution in a Core

- Unusual Withdrawing of a Control Rod during Reactor Startup Operation
- Unusual Withdrawing of a Control Rod during Rated Power Operation
- Unusual Dilution of a Boric Acid Solution in a Coolant

(2) Abnormal Change of Heat Generation or Heat Removal in a Core

- Loss of Commercial Power Line (External Power)
- Loss of Feed Flow
- Unusual Increasing of Steam Load
- Unusual Pressure Drop of Secondary Cooling System
- Excess Feed into Steam Generator

(3) Abnormal Change of Coolant Pressure or Coolant Possession Amount

- Miss Startup of ECCS during Rated Operation



Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant
 - 1.1 Reactor Core
(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)
 - 1.2 Emergency Core Cooling System (ECCS)
 - 1.3 Fuel Storage Facility
2. Exposure Evaluation of General Public around NPP
3. Analysis of Abnormal Transient Change (Incident) during Normal Operation
- 4. Analysis of Accident**
5. Analysis of Hypothetical Accident for Siting Evaluation
6. Technical Capability



Analysis Events for Accident Evaluation

(1) Loss of Coolant or Remarkable Change of Cooling State

- Loss of a Reactor Coolant
- Axial Sticking of a Primary Cooling Circulation Pump
- Rupture of Main Feed Piping
- Rupture of Main Steam Piping

(2) Abnormal Input of Reactivity or Rapid Change of Reactor Power

- Rapid Withdrawing of a Control Rod

(3) Unusual Releasing of Radioactive Materials into Environment

- Damage of Radioactive Waste Disposal Facility
- Rapture of Heat Transfer Tube of Steam Generator
- Loss of a Reactor Coolant

(4) Abnormal Change of Pressure or Environment of Containment Vessel

- Loss of a Reactor Coolant
- Generating of Combustible Gas



Example of Analysis Results (1): Loss of Coolant in BWR (Influence to Circumference)

<Screening Point>

Doesn't an accident affect to environment even if radioactive materials are released into environment by rupturing of main steam piping?


(3) Blowout of steam is stopped by closing of isolation valves.

(1) Contaminated steam are flows out into facility by rupturing of main steam piping.

(2) Radioactive materials are released into environment.

Analysis Results

Even if radioactive materials are released into environment by rupturing of main steam piping, dose rate will be controlled to slight **0.09mSv**.





Example of Analysis Results (1): Loss of Coolant in PWR (Influence to Circumference)

<Screening Point>

Doesn't an accident affect to environment even if radioactive materials are released into environment by leaking of primary coolant into out of the system?

Fifth Barrier (Concrete Shield Wall)

Fourth Barrier (Containment Vessel)

Analysis Results

Even if radioactive materials are released into environment, its influence is restrained below the allowable value by effect of five barriers.

Third Barrier (Reactor Vessel)

First Barrier (Fuel Pellet)

Second Barrier (Fuel Cladding Tube)

- ◆ Effective Dose Rate: at $0.23\text{mSv} \leq 5\text{mSv}$ (for Rupture of Primary Piping)
- ◆ Effective Dose Rate: at $0.29\text{mSv} \leq 5\text{mSv}$ (for Rupture of SG Heat Transfer Tube)



Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant
 - 1.1 Reactor Core
(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)
 - 1.2 Emergency Core Cooling System (ECCS)
 - 1.3 Fuel Storage Facility
2. Exposure Evaluation of General Public around NPP
3. Analysis of Abnormal Transient Change (Incident) during Normal Operation
4. Analysis of Accident
- 5. Analysis of Hypothetical Accident for Siting Evaluation**
6. Technical Capability



Analysis of Hypothetical Accident for Siting Evaluation

<Analysis Events>

- 1) Rupture of SG Heat Transfer Tube (As for Major Accident)
- 2) Loss of Coolant (AS for Hypothetical Accident)

<Guide for Judgment>

Major Accident

- ◆ For Thyroid Gland (Child): 1.5Sv
- ◆ For Whole Body: 0.25Sv

Hypothetical Accident

- ◆ For Thyroid Gland (Adult): 3.0Sv
- ◆ For Whole Body: 0.25Sv

<Analysis Results>

Analysis Events	Parts	Analysis Results	Standard
Major Accident	Thyroid Gland (Child)	at. $1.3 \times 10^{-2} \text{Sv}$	1.5Sv
	Whole Body	at. $3.5 \times 10^{-4} \text{Sv}$	0.25Sv
Hypothetical Accident	Thyroid Gland (Adult)	at. $1.3 \times 10^{-1} \text{Sv}$	3.0Sv
	Whole Body	at. $1.1 \times 10^{-2} \text{Sv}$	0.25Sv



Example Concrete Screening Items in Safety Assessment

1. Safety Design of Reactor Plant
 - 1.1 Reactor Core
(Mechanical Design, Nuclear Design, Thermal-Hydraulic Design)
 - 1.2 Emergency Core Cooling System (ECCS)
 - 1.3 Fuel Storage Facility
2. Exposure Evaluation of General Public around NPP
3. Analysis of Abnormal Transient Change (Incident) during Normal Operation
4. Analysis of Accident
5. Analysis of Hypothetical Accident for Siting Evaluation
- 6. Technical Capability**



Analysis of Hypothetical Accident for Siting Evaluation

<Analysis Items>

- 1) Organization for Design and Construction
- 2) Provision of Engineers for Design and Construction
- 3) Experience of Design and Construction
- 4) Quality Assurance Activity related to Design and Construction
- 5) Organization for Operation and Maintenance
- 6) Provision of Engineers for Operation and Maintenance
- 7) Experience for Operation and Maintenance
- 8) Quality Assurance Activity related to Operation and Maintenance
- 9) Education and Training for Engineer
- 10) Appointment and Arrangement of Qualified Persons



6. Comparison with Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants

The contents of attachment material of application for installation permission of NPP mentioned in the next page is mostly in accordance with “**Standard Review Plan for the Review of Safety Analysis Reports for NPP: LWR Edition**” by U.S.NRC (USA Nuclear Regulatory Committee).
<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800>

Contents of Safety Analysis Reports (1/2)

- ✓ Chapter-1: Introduction and Interfaces → Attachment-1-5 & 7
 - ✓ Chapter-2: Sites Characteristics and Site Parameters → Attachment-6 (Climate, Foundation, Earthquake...)
 - ✓ Chapter-3: Design of Structure, Components, Equipments and Systems (→ See sample in p20)
 - ✓ Chapter-4: Reactor (→ See sample in p22)
 - ✓ Chapter-5: Reactor Coolant System, and Connected System
 - ✓ Chapter-6: Engineered Safety Features
 - ✓ Chapter-7: Instrumentation and Controls
 - ✓ Chapter-8: Electric Power
 - ✓ Chapter-9: Auxiliary Systems
 - ✓ Chapter-10: Steam and Power Conversion System
- } Attachment-8 (Safety Design)



Contents of Safety Analysis Reports (2/2)

- ✓ Chapter-11: Radioactive Waste Management
 - ✓ Chapter-12: Radiation Protection
 - ✓ Chapter-13: Conduct of Operators
 - ✓ Chapter-14: Initial Test Program and ITACC-Design Certification
 - ✓ Chapter-15: Transient and Accident Analysis
 - ✓ Chapter-16: Technical Specifications
 - ✓ Chapter-17: Quality Assurance
 - ✓ Chapter-18: Human Factors Engineering
 - ✓ Chapter-19: Severe Accidents
- Attachment-9
 (Radiation Management &
 Disposal of Radioactive Waste)
- Operational Safety Program
- Attachment-10
 (Safety Assessment)
- Operational Safety Program
- Attachment-8
 (Safety Design)
- Attachment-10
 (Safety Assessment)


(Remark)

Please **refer to appendix-1** for the **sample of safety analysis** report based on the standard review plan for the review of safety analysis reports for NPP: LWR edition (U.S.NRC)



Sample: Chapter-3 Design of Structure, Components, Equipments & Systems

[Index](#) | [Site Map](#) | [FAQ](#) | [Facility Info](#) | [Reading Rm](#) | [New](#) | [Help](#) | [Glossary](#) | [Contact Us](#)



Protecting People and the Environment

About NRC
Nuclear Reactors
Nuclear Materials
Radioactive Waste
Nuclear Security
Public Meetings & Involvement

- NUREG-0800**
- Cover, Contents, Introduction
- Chapter 1
- Chapter 2
- Chapter 3
- Chapter 4
- Chapter 5
- Chapter 6
- Chapter 7
- Chapter 8
- Chapter 9
- Chapter 10
- Chapter 11
- Chapter 12
- Chapter 13
- Chapter 14
- Chapter 15
- Chapter 16
- Chapter 17
- Chapter 18
- Chapter 19
- Appendices
- Bibliographic Data Sheet
- Review Branches

Home > [Electronic Reading Room](#) > [Document Collections](#) > [NUREG-Series Publications](#) > [Staff Reports](#) > [NUREG-0800](#) > Chapter 3

Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition – Design of Structures, Components, Equipment, and Systems (NUREG-0800, Chapter 3)

The following links on this page are to documents in our [Agencywide Documents Access and Management System \(ADAMS\)](#). ADAMS documents are provided in either Adobe Portable Document Format (PDF) or Tagged Image File Format (TIFF). To obtain free viewers for displaying these formats, see our [Plugins, Viewers, and Other Tools](#). If you have problems with viewing or printing documents from ADAMS, please contact the [Public Document Room staff](#).

Section	Title	Rev.	Date Updated
3.2.1	Seismic Classification	Rev. 2	03/2007
		Draft Rev. 2	06/1996
		Rev. 1	07/1981
		Rev. 0	11/1975
3.2.2	System Quality Group Classification	Rev. 2	03/2007
		Draft Rev. 2	06/1996
		Rev. 1	07/1981
		Rev. 0	11/1975
3.3.1	Wind Loadings	Rev. 3	03/2007
		Draft Rev. 3	06/1996
		Rev. 2	07/1981
		Rev. 1	08/1978
		Rev. 0	11/1975
3.3.2	Tornado Loadings	Rev. 3	03/2007
		Draft Rev. 3	06/1996
		Rev. 2	07/1981
		Rev. 1	08/1978

see next page



Sample: Chapter-3 Design of Structure, Components, Equipments & Systems

NUREG-0800



U.S. NUCLEAR REGULATORY COMMISSION STANDARD REVIEW PLAN

3.2.1 SEISMIC CLASSIFICATION

REVIEW RESPONSIBILITIES

Primary - Organization responsible for mechanical engineering reviews

Secondary - Organizations responsible for the review of component performance and testing.

I. AREAS OF REVIEW

General Design Criterion (GDC) 2 of 10 CFR Part 50, Appendix A, in part, requires that structures, systems, and components (SSCs) important to safety be designed to withstand the effects of earthquakes without loss of capability to perform their safety functions. The earthquake against which these plant features are designed is defined as the safe shutdown earthquake (SSE) in 10 CFR Part 100, Appendix A, and 10 CFR Part 50, Appendix S. The SSE is based upon an evaluation of the maximum earthquake potential and is that earthquake which produces the maximum vibratory ground motion for which SSCs important to safety are designed to remain functional. Appendix S also requires consideration of surface deformation. Those plant features that are designed to remain functional if an SSE occurs are designated Seismic Category I in Regulatory Guide (RG) 1.29.



Sample: Chapter-4 Reactor

U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

About NRC
Nuclear Reactors
Nuclear Materials
Radioactive Waste
Nuclear Security
Public Meetings & Involvement

- NUREG-0800
- Cover, Contents, Introduction
- Chapter 1
- Chapter 2
- Chapter 3
- Chapter 4
- Chapter 5
- Chapter 6
- Chapter 7
- Chapter 8
- Chapter 9
- Chapter 10
- Chapter 11
- Chapter 12
- Chapter 13
- Chapter 14
- Chapter 15
- Chapter 16
- Chapter 17
- Chapter 18
- Chapter 19
- Appendices
- Bibliographic Data Sheet
- Review Branches

Home > Electronic Reading Room > Document Collections > NUREG-Series Publications > Staff Reports > NUREG-0800 > Chapter 4

Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition – Reactor (NUREG-0800, Chapter 4)

The following links on this page are to documents in our [Agencywide Documents Access and Management System \(ADAMS\)](#). ADAMS documents are provided in either Adobe Portable Document Format (PDF) or Tagged Image File Format (TIFF). To obtain free viewers for displaying these formats, see our [Plugins, Viewers, and Other Tools](#). If you have problems with viewing or printing documents from ADAMS, please contact the [Public Document Room staff](#).

Section	Title	Rev.	Date Updated
4.2	Fuel System Design	Rev. 3	03/2007
		Draft Rev. 3	06/1996
		Rev. 2	07/1981
		Rev. 1	09/1978
		Rev. 0	11/1975
4.3	Nuclear Design	Rev. 3	03/2007
		Draft Rev. 3	06/1996
		Rev. 2	07/1981
		Rev. 1	04/1978
		Rev. 0	11/1975
4.4	Thermal and Hydraulic Design	Rev. 2	03/2007
		Draft Rev. 2	06/1996
		Rev. 1	07/1981
		Rev. 0	11/1975
4.5.1	Control Rod Drive Structural Materials	Rev. 3	03/2007
		Draft Rev. 3	06/1996
		Rev. 2	07/1981
		Rev. 1	01/1978

Fuel System Design

→ see next page



Sample: Chapter-4 Reactor



U.S. NUCLEAR REGULATORY COMMISSION STANDARD REVIEW PLAN

4.2 FUEL SYSTEM DESIGN

REVIEW RESPONSIBILITIES

Primary - The organization responsible for the review of transient and accident analyses

Secondary - None

I. AREAS OF REVIEW

The organization responsible for the review of transient and accident analyses evaluates the thermal, mechanical, and materials design of the fuel system. The fuel system consists of arrays (assemblies or bundles) of fuel rods, including fuel pellets, insulator pellets, springs, tubular cladding, end closures, hydrogen getters, and fill gas; burnable poison rods including components similar to those in fuel rods; spacer grids and springs; end plates; channel boxes; and reactivity control rods. This section discusses the reactivity control elements of the control rods that extend from the coupling interface of the control rod drive mechanism into the core.

The fuel system safety review provides assurance that (1) the fuel system is not damaged as a result of normal operation and anticipated operational occurrences (AOOs), (2) fuel system damage is never so severe as to prevent control rod insertion when it is required. (3) the




Appendix

Preliminary Safety Analysis Report (PSAR)

(Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition)

- Country: Taiwan
- Power Plant: Longmen N.P.P (ABWR) No.1 & No.2
- Output Power: 2,700 MWe (1,350MWe/unit)
- Start of Commercial Operation: December 2011 (Unit-No.1)
December 2012 (Unit-No.2)



Implementation of Preliminary Safety Analysis based on LWR Edition (NUREG-0800, Formerly issued as NUREG-75/087)

<http://www.nucleartourist.com/psar/index.html>



Safety Analysis Reports (1/10)

Safety Analysis Reports

Nuclear power plant operators, i.e. licensees, are expected to maintain updated safety analysis reports on how the plant is designed, operated, and maintained. Initially, a Preliminary Safety Analysis Report (PSAR) must be filed with the regulatory agency. The agency reviews the information, asks questions, and may specify changes in the plant design or additional requirements. After the plant receives its operating license, the report is often referred to as the Final (or Updated) Safety Analysis Report.

Updated copies of these reports are maintained in the local public document center, usually a public library near the plant. In the United States, the safety analyses reports are reviewed using [NUREG-0800, Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants](#), as a guide. NUREG-0800 identifies the requirements that the NRC expects the power plant operator to comply with.

[No Nukes Asia Forum Japan](#) has graciously provided the [Lungmen Power Plant Units 1 and 2 Preliminary Safety Analysis Report](#) on their website. The Table of Contents links below lead to the various chapters of the report that are available. This report is typical of the information that a utility is expected to provide to the regulatory agency. In this specific case, the Taiwan nuclear laws require compliance with the same US Nuclear Regulatory Commission standards as US plants must meet.

The table of contents below provides additional information unavailable on the linked site. Total volume of the PSAR is about 87 MB and includes hundreds of drawings and tables. Practically all the documents are PDF files that can be read using [Adobe](#) Acrobat. In a few cases, the documents are DOC files that can be read using [Microsoft](#) Word. The DOC type documents are identified in the table of contents (e.g. Chapter 11).

[Complete PSAR Table of Contents and Acronyms](#)

Preliminary Safety Analysis Report (PSAR)





Safety Analysis Reports (2/10)

1.0 Introduction and General Description of Plant

[Chapter 1 Table of Contents](#)

[Chapter 1 List of Tables](#)

[Chapter 1 List of Figures](#)

[1.1 Introduction and General Description of Plant](#)

[1.2 General Plant Description](#)

[1.3 Comparison Tables](#)

[1.4 Identification of Agents and Contractors](#)

[1.5 Requirements for Further Technical Information](#)

[1.6 GE Topical Reports and Other Documents](#)

[1.7 Drawings](#)

[1.8 Conformance with Standard Review Plan and Applicability of Codes and Standards](#)

[1A. Response to TMI Related Matters](#)

[1AA Plant Shielding to Provide Access to Vital Areas and Protective Safety Equipment for Post-Accident Operation \[II.B.2\]](#)

[1B. Response to Construction Permit or Manufacturing License \(CP/ML\) Rule 10 CFR 50.34\(f\)](#)

[1C. Resolution of Applicable Unresolved Safety Issues and Generic Safety Issues](#)

[1D. Lungmen Nuclear Power Station \(NPS\) Station Blackout Considerations \(SBO\)](#)

2.0 Site Characteristics

[Chapter 2 Table of Contents](#)

[Chapter 2 List of Tables](#)

[Chapter 2 List of Figures](#)

[2.1 Geography and Demography](#)

[2.2 Nearby Industrial, Transportation, and Military Facilities](#)

[2.3 Meteorology](#)

[2.3 Tables](#)

[2.4 Hydrologic Engineering](#)

[2.5 Geology, Seismology, and Geotechnical Engineering](#)

[2.5 Tables](#)





Safety Analysis Reports (3/10)

3.0 Design of Structures, Components, Equipment and Systems

[Chapter 3 Table of Contents](#)

[Chapter 3 List of Tables](#)

[Chapter 3 List of Figures](#)

[3.1 Conformance with USNRC Design Criteria](#)

[3.2 Classification of Structures, Components, and Systems](#)

[3.3 Wind and Typhoon Loadings](#)

[3.4 Winter Level \(Flood\) Design](#)

[3.5 Missile Protection](#)

[3.6 Protection Against Dynamic Effects Associated with the Postulated Rupture of Piping](#)

[3.7 Seismic Design](#)

[3.8 Seismic Category I Structures](#)

[3.9 Mechanical Systems and Components](#)

[3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment](#)

[3.11 Environmental Qualification of Safety-Related Mechanical and Electrical Equipment](#)

[3A Seismic Soil Structure Interaction Analysis](#)

[3B Containment Hydrodynamic Loads](#)

[3C Computer Programs Used in the Design and Analysis of Seismic Category I Structures](#)

[3D Computer Programs Used in the Design of Components, Equipment and Structures](#)

[3E Not Used](#)

[3F Not Used](#)

[3G Response of Structures to Containment Loads](#)

[3H Design Details and Evaluation Results of Seismic Category I Structures](#)

[3I Equipment Qualification Environmental Design Criteria](#)

[3J Not Used](#)

[3K Not Used](#)

[3L Evaluation of Postulated Ruptures in High Energy Pipes](#)

[3M Intersystem Loss Of Coolant Accident For Lungmen NPS.....](#)

[3MA System Evaluation For ISLOCA](#)



Safety Analysis Reports (4/10)

4.0 Reactor

[Chapter 4 Table of Contents](#)

[Chapter 4 List of Tables](#)

[Chapter 4 List of Figures](#)

[4.1 Summary Description](#)

[4.2 Fuel System Design](#)

[4.3 Nuclear Design](#)

[4.4 Thermal-Hydraulic Design](#)

[4.5 Reactor Materials](#)

[4.6 Functional Design of Reactivity Control System](#)

[4A Typical Control Rod Patterns and Associated Power Distribution for Lungmen NPS](#)

[4B Not Used](#)

[4C Control Rod Licensing Acceptance Criteria](#)

[4D Reference Fuel Design Compliance with Acceptance Criteria](#)

5.0 Reactor Coolant System and Connected Systems

[Chapter 5 Table of Contents](#)

[Chapter 5 List of Tables](#)

[Chapter 5 List of Figures](#)

[5.1 Summary Description](#)

[5.2 Integrity of Reactor Coolant Pressure Boundary \(RCPB\)](#)

[5.3 Reactor Vessel](#)

[5.4 Component and Subsystem Design](#)

[5A Method of Compliance for Regulatory Guide 1.150](#)

[5B RHR Injection Flow and Heat Capacity Analysis Outlines](#)





Safety Analysis Reports (5/10)

6 Engineered Safety Features

[Chapter 6 Table of Contents](#)

[Chapter 6 List of Tables](#)

[Chapter 6 List of Figures](#)

[6.0 Engineered Safety Features](#)

[6.1 Engineered Safety Feature Materials](#)

[6.2 Containment Systems](#)

[6.3 Emergency Core Cooling Systems](#)

[6.4 Habitability Systems](#)

[6.5 Fission Products Removal and Control Systems](#)

[6.6 Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping](#)

[6.7 High Pressure Nitrogen Gas Supply System](#)

[6A Regulatory Guide 1.52, Section C, Compliance Assessment](#)

[6B SRP 6.5.1, Table 6.5.1-1 Compliance Assessment](#)

[6C Containment Debris Protection for ECCS Strainers](#)

[6D. Additional Bypass Leakage Considerations](#)

7.0 Instrumentation and Control Systems

[Chapter 7 Table of Contents](#)

[Chapter 7 List of Tables](#)

[Chapter 7 List of Figures](#)

[7.1 Introduction](#)

[7.2 Reactor Trip System – Instrumentation and Controls](#)

[7.3 Engineered Safety Feature Systems – Instrumentation and Control](#)

[7.4 Safe Shutdown Systems](#)

[7.5 Information Systems Important to Safety](#)

[7.6 Interlock Systems Important to Safety](#)

[7.7 Control Systems](#)

[7.8 Diverse Instrumentation and Control Systems](#)

[7.9 Data Communication Systems](#)





Safety Analysis Reports (6/10)

8.0 Electric Power

[Chapter 8 Table of Contents](#)

[Chapter 8 List of Tables](#)

[Chapter 8 List of Figures](#)

[Chapter 8 Proprietary Information](#)

[8.1 Introduction](#)

[8.2 Offsite Power Systems](#)

[8.3 Onsite Power Systems](#)

[Figure 8.3-1 Electrical Power Distribution System Plant One Line Diagram](#)

[8A Miscellaneous Electrical Systems](#)

[8A1 Station Grounding and Surge Protection](#)

[8A2 Cathodic Protection](#)

[8A3 Electric Heat Tracing](#)

[8A4 References](#)

9.0 Auxiliary Systems

[Chapter 9 Table of Contents](#)

[Chapter 9 List of Tables](#)

[Chapter 9 List of Figures](#)

[9.1 Fuel Storage and Handling](#)

[9.2 Water Systems](#)

[9.3 Process Auxiliaries](#)

[9.4 Air Conditioning, Heating, Cooling, and Ventilating Systems](#)

[9.5 Other Auxiliary Systems](#)

[9A Fire Hazard Analysis](#)

[9A1 Introduction](#)

[9A2 Analysis Criteria](#)

[9A3 Analysis Approach](#)

[9A4 Analysis](#)

[9A4 Figures – Turbine Building Fire Protections](#)

[9A5 Special Cases](#)

[9A6 Fire Hazard Analysis Database](#)

[9B Summary of Analysis Supporting Fire Protection Design Requirements](#)

[9C Regulatory Guide 1.52, Section C, Compliance Assessment](#)

[9D SRP 6.5.2, Table 6.5.1-1 Compliance Assessment](#)





Safety Analysis Reports (7/10)

10.0 Steam and Power Conversion System

[Chapter 10 Table of Contents](#)

[Chapter 10 List of Tables](#)

[Chapter 10 List of Figures](#)

[10.1 Summary Description](#)

[10.2 Turbine Generator](#)

[10.3 Main Steam Supply System](#)

[10.4 Other Features of Steam and Power Conversion System](#)

[Heat Balance Diagrams for Design Flow and 105% Design Flow Conditions](#)

11.0 Radioactive Waste Management

[Chapter 11 Table of Contents \(Word file\)](#)

[Chapter 11 List of Tables \(Word file\)](#)

[Chapter 11 List of Figures \(Word file\)](#)

[11.1 Source Terms](#)

[11.2 Liquid Radwaste System](#)

[11.3 Gaseous Radioactive Waste Processing System](#)

[11.4 Solid Waste Management System](#)

[11.5 Process and Effluent Radiological Monitoring and Sampling System](#) [11.6 Offsite Radiological Monitoring Program](#)

12.0 Radiation Protection

[Chapter 12 Table of Contents](#)

[Chapter 12 List of Tables](#)

[Chapter 12 List of Figures](#)

[12.1 Ensuring that Occupational Radiation Exposures are ALARA](#)

[12.2 Radiation Sources](#)

[12.3 Radiation Protection Design Features](#)

[12.4 Dose Assessment](#)

[12.5 Health Physics Program](#)

[12A Calculation of Airborne Radionuclides](#)





Safety Analysis Reports (8/10)

13.0 Conduct of Operations

[Chapter 13 Table of Contents](#)

[Chapter 13 List of Tables](#)

[Chapter 13 List of Figures](#)

[13.1 Organizational Structure of Applicant](#)

[13.2 Training](#)

[13.3 Emergency Planning](#)

[13.4 Review and Audit](#)

[13.5 Plant Procedures](#)

[13.6 Physical Security](#)

14.0 Initial Test Program

[Chapter 14](#)

[Table of Contents](#)

[List of Tables](#)

[List of Figures](#)

[14.0 Initial Test Program](#)

[14.1 Specific Information to be Included in Preliminary Safety Analysis Reports](#)

[14.2 Specific Information to be Included in Final Safety Analysis Reports](#)

15.0 Accident and Analysis

[Chapter 15 Table of Contents](#)

[Chapter 15 List of Tables](#)

[Chapter 15 List of Figures 1](#)

[Chapter 15 List of Figures 2](#)

[15.0 Accident and Analysis General](#)

[15.1 Decrease in Reactor Coolant Temperature](#)

[15.2 Increase in Reactor Coolant Pressure](#)

[15.3 Decrease in Reactor Coolant System Flow Rate](#)

[15.4 Reactivity and Power Distribution Anomalies](#)

[15.5 Increase in Reactor Coolant Inventory](#)

[15.6 Decrease in Reactor Coolant Inventory](#)

[15.7 Radioactive Release from Subsystems and Component](#)

[15.8 Anticipated Transients Without Scram](#)

[15A Plant Nuclear Safety Operational Analysis \(NSOA\)](#)

[15B Failure Modes and Effects Analysis \(FMEA\)](#)





Safety Analysis Reports (9/10)

16.0 Preliminary Technical Specifications (PSAR)

[Volume 2 Technical Specification Bases](#)

17 Quality Assurance

[Table of Contents](#)

[17.1 Introduction](#)

[17.1A Quality Assurance During Design and Construction \(TPC\)](#)

[17.1B Quality Assurance During Design and Construction \(GE\)](#)

[17.1C Quality Assurance During Design and Construction \(S&W\)](#)

[17.2 Quality Assurance During the Operations Phase](#)

[17.3 Reliability Assurance Program](#)

[Attachments 17A, 17B, 17C](#)

17A TPC Nuclear Projects Quality Assurance Program

17B Quality Assurance Program for Lungmen Nuclear Power Project (GE)

17C Quality Assurance Program for Lungmen Nuclear Power Project (S&W)

18.0 Human Factors Engineering

[Chapter 18](#)

18.0 Human Factors Engineering

18.1 Introduction

18.2 Design Goals and Design Bases

18.3 Planning, Development, and Design

18.4 Control Room Standard Design Features

18.5 Remote Shutdown System

18.6 Systems Integration

18.7 Human-System Interface (HSI) Design Implementation



Safety Analysis Reports (10/10)

19.0 Severe Accident Analysis

[Chapter 19 Table of Contents](#)

[Chapter 19 List of Tables](#)

[Chapter 19 List of Figures](#)

[19.1 Introduction](#)

[19.2 Overview](#)

[19.3 Assessment of Severe Accident Prevention](#)

[19.4 Assessment of Severe Accident Mitigation](#)

[19.5 Containment Performance](#)

[19.6 Severe Accident Management](#)

[19.7 Capacity of Primary Containment](#)

Appendices

Appendix A Probabilistic Risk Assessment

[A1 Executive Summary](#)

[A2 Purpose and Scope](#)

[A3 Plant Design Features and Operator Actions Included in the Risk Model](#)

[A4 Initiating Events and Systems Success Criteria](#)

[A5 Internal Events Analysis](#)

[A6 External Events Analysis](#)

[A7 Shutdown Analysis](#)

[A8 Systems Fault Tree Analysis](#)

[A9 Level 1 PRA Input Data](#)

[A10 Human Reliability Analysis](#)

[A11 Core Damage Frequency](#)

[A12 Accident Sequence Grouping And Containment Reliability Analysis](#)

[A13 Containment Event Tree Analysis and Release Categories](#)

[A14 Source Term and Containment Release Categories](#)

[A15 Off-Site Consequences and Risk Analysis](#)

[A16 Design Features and Operator Actions Important to Risk](#)

[A17 Conclusion](#)

[AA Fault Tree Analysis](#)

[AB Event Tree Analysis](#)

[AC Seismic Analysis](#)

[AD Probabilistic Fire Analysis](#)

[AF Flooding Analysis](#)

